

AMENDMENT-1

TO

DOC#: KRCD-PF4-RFQ-2022-01

(RFQ- OWNER'S ENGINEERING SERVICES FOR UNIT 4 ADDITION TO THE JEFF L.
TAYLOR PINE FLAT POWER PLANT)



Prepared by:
Kings River Conservation District
4886 E. Jensen Avenue
Fresno, California 93725
<https://krcd.org/>

This Amendment Release Date: 4/8/2022

The following amendments and clarifications are made to the latest release of the RFQ FOR OWNER'S ENGINEERING SERVICES FOR UNIT 4 ADDITION TO THE JEFF L. TAYLOR PINE FLAT POWER PLANT (DOC#: KRCD-PF4-RFQ-2022-01, REV-2)

Amendment 1.1 : RFQ section 3 "Project Development" –

Since no appendices were included to the RFQ release due to the confidentiality nature of these documents, second paragraph in this section is further clarified below-

"Appendix-A would have been for a preliminary single line for the project and a markup with "supply scope limit" for the water to wire equipment vendor. The equipment vendor shall supply all equipment starting at the Generator/Turbine up to the Unit Switchgear- the package will include PLC based Control system, governor, exciter, HPUs, Turbine Inlet Valve, draft tube and other auxiliary equipment. Anything upstream to the unit switchgear that would mostly be High Voltage (HV) switchyard equipment is currently not planned under the vendor's scope. These would include 13.8/230kV step-up transformer, 230kV switchgear system and transmission line interconnect equipment (Surge Arresters, disconnect switches, revenue meter, etc.)."

Amendment 1.2 : RFQ section 4.4.7 "Construction Phase" –

The section is further clarified as follows-

"Inspection services will include on-site participation during commissioning phase, as requested by KRCD for specific equipment or Unit-4 as a whole. A list of certifications (that could be PE license or any relevant specific equipment test/commissioning" certification) shall be included. Responding firms shall just list the certification in the response to the RFQ and that the copies of certifications are only required before signing the contract with the selected firm."

Amendment 1.3 : RFQ section 8.C.6 "References" –

The change from the last RFQ release is underlined below; there are no other changes to this section-

"Responding firms shall provide a minimum of three (3) references from different clients for engagements performed in the last ten (10) years where the services provided were the same or similar in nature to the services requested herein."

Amendment 1.4 : RFQ section 8.C.9 "Exceptions and Clarifications" –

The section shall be amended as follows-

"RFQ response shall include exceptions and clarifications, if any. Responders shall include any exceptions to their capabilities in performing the requested services for a "small hydroelectric" project of size and nature. Responders shall also include any exceptions they want to take to the minimum scope of work requested in the RFQ. Examples of clarifications can be reason behind the use of sub-consultants. There is no defined format or a list for the responders to fill out for this section."